

THE NATIONAL BOARD

OF BOILER AND

PRESSURE VESSEL

INSPECTORS

April 1, 2010

Mr. Paul Heald Valvtechnologies, Incorporated 5904 Bingle Rd Houston, TX 77092

Subject:

Capacity Certification, Valve Type Z***21N7BWRA6P1-MK1B

(NB Cap. Cert ID No.: VLC-M59093)

Dear Mr. Heald,

Please find enclosed copies of test numbers 28274S through 28277S performed on April 1, 2010 at the National Board Testing Laboratory for the purpose of obtaining capacity certification of the subject valve type as required by paragraph PG-69.3 of Section I of the ASME Code. Steam was the test medium.

This is a power operated valve which was manually opened and tested for flow rate only. Four tests were performed and an average slope of 137.7 PPH/PSIA was determined. All four tests had a measured slope within the +/-5% acceptance criteria. Based upon this testing, Valvtechnologies, Inc. can use a rated slope of no higher than 123.9 PPH/PSIA (137.7 x 0.9) for capacity rating of this design.

Valvtechnologies, Incorporated is hereby granted capacity certification and authorization to apply the "NB" mark to the valve type listed in the scope of certification. This authorization is valid for the above location and only while the organization holds a current ASME "V" Certificate of Authorization and is fully implementing its quality system as accepted by the National Board.

SCOPE OF CERTIFICATION

VALVE TYPE: Z***21N7BWRA6P1-MK1B

Organization Type: Manufacturer

Certified Rating Value: Slope = 123.9 PPH/PSIA

Size: 2-1/2" x 4"

Pressure Range: 35 through 5000 psig

Certification Expiration Date: April 1, 2015

1055 CRUPPER AVE,

COLUMBUS, OHIO

43229-1183

⊔.s.A.

614.888.8320

EXECUTIVE Fax 614 888 0750

TECHNICAL Fax 614.847.1828

PRESSURE RELIEF DEPT.

DRDER DEPARTMENT Fax 614 847 1147

TRAINING DEPARTMENT Fax 614 847 5542

EMAIL information@nationalboard.org

WEB SITE

Yours truly,

Joseph F. Ball, P. E.

Director, Pressure Relief Department

REF: VLC-M59093ini4-10.doc

Provisional Testing at NBBI Testing Lab

Steam Test Report—Timed Weight Method

Valvetechnologies, Incorporated

Valve Type Z***21NTBWRA6P1-MK1B

1.871

Provisional Test Series

28277S

Test Orif. Size Set Pressure Slope Within **PSIG** No. Inches PPH/PSIA Range? 28274S 1.871 35 140.6 Yes 28275S 1.871 55 137.0 Yes 28276S 1.871 65 136.7 Yes

80


Average Slope 137.614 PPH/PSIA +5% Slope 144,494 PPH/PSIA -5% Slope 130.733 PPH/PSIA

136.2

Yes

90% Slope 123.852 PPH/PSIA

VLC-M59093



Notes:

I certify that the data on the attached test data sheet(s) was obtained under my supervision in accordance with the provisions of ANSI/ASME PTC 25, the applicable sections of the ASME Boiler and Pressure Vessel Code, and the National Board Testing Laboratory Quality Control Manual. To the best of my knowledge and belief the objects tested were of the same type and design as indicated.

4-1-10 DATE Authorized Observ

Test Personnel:

T. Brown

D. Hennon

S. Irwin

Company Representatives

^{1.} Valves tested for initial capacity certification per paragraph PG-69.2.2 of Section I, ASME Boiler and Pressure Vessel Code.

	Valve ID Data		C:\Data\Steam Tests\28274S.xls
1	Test Number	28274S	
2	Test Sponsor	Valvtechnologies, Incorporated	d
3	Company Type	Manufacturer	Houston, TX
4	Test Date	4/1/2010	VLC
5	Valve Type	Z***21N78WRA6P1-MK1B	
6	Manufacturer	Valvtechnologies, Incorporated	
7	Cap. Cert. ID No.	59093	
8	Set Pressure		
9	Inlet Size	3 FI	
10	Outlet Size	4 FI	
Ĩ1	Stamped Capacity		
12	Code Section	1	
13	Serial Number		
14	Date Code		
	Operational Data and Measured D	imensions	
15	Warn Pressure	psig	
16	Set Pressure	psig	
17	Reset Set Pressure	psig	
18	Blowdown	psi	
19	Reset Blowdown	psi	
20	Bore Diameter	1.871 inch	
21	Lift	inch	
	Measured Data		
22	Flow Area	2.7494 in ²	
23	Vessel Pressure	35.0 psig	
24	P _b	14.26 psia	
25	Calorimeter Temp.	265.8 °F	
26	Time of Run	4.0 minutes	
27	Weight	460.1 lbm	
28	Leakage	0.0 PPH	
	Calculated Data		
29			
30	Vessel Pressure	49.3 psia	
31	Enthalpy, calorimeter	1,176.5 BTU/lbm	
32	Saturation Temp., Vessel	280.1 °F	
33	Saturation Volume, Vessel	20011	
34	Steam Quality, Vessel		
35	Vessel Temp. (Theoretical)	20 110	
36	Vessel Volume		
37	Degrees Superheat	110	
38	Capacity Correction	1.0038	
39	Measured Capacity	6927.8 PPH	Λ
40	Slope	140.638 PPH/PSI	Α
41	Coefficient	0.99325	
42	Rated Capacity For Measured Set	N/A PPH	
43		in ²	
44		in	

	Valve ID Data		C:\Data\Steam Tests\28275S.xls
1	Test Number	28275S	
2	Test Sponsor	Valvtechnologies, Incor	porated
3	Company Type	Manufacturer	Houston, TX
4	Test Date	4/1/2010	VLC
5	Valve Type	Z***21N7BWR6P1-MK1B	3
6	Manufacturer	Valvtechnologies, Incorpo	orated
7	Cap. Cert. ID No.	59093	
8	Set Pressure		
9	Inlet Size	3 FI	
10	Outlet Size	4 FI	
11	Stamped Capacity		
12	Code Section	I	
13	Serial Number		
14	Date Code		
	Operational Data and Measured D	imensions	
15	Warn Pressure	ps	sig
16	Set Pressure		sig
17	Reset Set Pressure		sig
18	Blowdown	p	
19	Reset Blowdown	ps	
20	Bore Diameter		ich
21	Lift		ich
	Measured Data		
22	Flow Area	2.7494 in	2
23	Vessel Pressure		sig
24	P _b		sia
		· ·	
25	Calorimeter Temp.	20110	
26	Time of Run		ninutes
27	Weight		om DLI
28	Leakage	0.0 P	PH
	Calculated Data		
29			
30	Vessel Pressure		sia
31	Enthalpy, calorimeter		TU/lbm
32	Saturation Temp., Vessel	302.2 °F	
33	Saturation Volume, Vessel		³ /lbm
34	Steam Quality, Vessel	100.0 %	
35	Vessel Temp. (Theoretical)	311.1 °F	
36	Vessel Volume		³/lbm
37	Degrees Superheat	8.9 °F	
38	Capacity Correction	1.0071	
39	Measured Capacity		PH
40	Slope		PH/PSIA
41	Coefficient	0.96757	
42	Rated Capacity For Measured Set		PH
43	, , ,		
44		in	2

	Valve ID Data			C:\Data\Steam Tests\28276S xls
1	Test Number	28276S		
2	Test Sponsor	Valvtechnolog	ies, Incorporated	
3	Company Type	Manufacturer		Houston, TX
4	Test Date	4/1/2010		VLC
5	Valve Type	Z***21N7BWEA	6P1-MK1B	
6	Manufacturer	Valvtechnologies, Incorporated		
7	Cap. Cert. ID No.	59093		
8	Set Pressure			
9	Inlet Size	3 Fl		
10	Outlet Size	4 Fl		
11	Stamped Capacity			
12	Code Section			
13	Serial Number			
14	Date Code			
	Operational Data and Measured D	imensions		
15	Warn Pressure		psig	
16	Set Pressure		psig	
17	Reset Set Pressure		psig	
18	Blowdown		psi	
19	Reset Blowdown		psi	
20	Bore Diameter	1.871	inch	
21	Lift	1.071	inch	
	Measured Data			
22	Flow Area	2.7494	in ²	
23	Vessel Pressure	65.1		
24		14.26	psig psia	
	P _b		°F	
25	Calorimeter Temp.	294.8		
26	Time of Run	4.0	minutes	
27	Weight	715.8	Ibm	
28	Leakage	0.0	PPH	
	Calculated Data			
29				
30	Vessel Pressure	79.4	psia	
31	Enthalpy, calorimeter	1,190.4	BTU/lbm	
32	Saturation Temp., Vessel	311.5	°F	
33	Saturation Volume, Vessel	5.5146	ft ³ /lbm	
34	Steam Quality, Vessel	100.0	%	
3 5	Vessel Temp. (Theoretical)	324.0	°F	
36	Vessel Volume	5.6263	ft ³ /lbm	
37	Degrees Superheat	12.5	°F	
38	Capacity Correction	1.0101		
39	Measured Capacity	10845.2	PPH	
40	Slope	136.659	PPH/PSIA	
41	Coefficient	0.96515		
42	Rated Capacity For Measured Set	N/A	PPH	
43		•		
44			in ²	

	Valve ID Data			C:\Data\Steam Tests\28277S.xl
1	Test Number	28277S		
2	Test Sponsor	Valvtechnolog	ies, Incorporated	
3	Company Type	Manufacturer		Houston, TX
4	Test Date	4/1/2010		VLC
5	Valve Type	Z***21N7BWRA	\6P1-MK1B	
6	Manufacturer	Valvtechnologie	es, Incorporated	
7	Cap. Cert. ID No.	59093		
8	Set Pressure			
9	Inlet Size	3 FI		
10	Outlet Size	4 FI		
11	Stamped Capacity			
12	Code Section			
13	Serial Number			
14	Date Code			
	Operational Data and Measured D	imensions		
15	Warn Pressure		psig	
16	Set Pressure		psig	
17	Reset Set Pressure		psig	
18	Blowdown		psi	
19	Reset Blowdown		psi	
20	Bore Diameter	1.871	inch	
21	Lift		inch	
	Measured Data			
22	Flow Area	2.7494	in ²	
23	Vessel Pressure	79.9	psig	
24	P _b	14.26	psia	
25	Calorimeter Temp.		°F	
26	Time of Run	291.8	minutes	
27		4.0 851.7	Ibm	
	Weight		PPH	
28	Leakage Colonidated Pate	0.0	FFN	
	Calculated Data			
29				
30	Vessel Pressure	94.2	psia	
31	Enthalpy, calorimeter	1,188.9	BTU/lbm	
32	Saturation Temp., Vessel	323.5	°F	
33	Saturation Volume, Vessel	4.6921	ft ³ /lbm	
34	Steam Quality, Vessel	100.0	%	
35	Vessel Temp. (Theoretical)	327.8	°F	
36	Vessel Volume	4.7252	ft³/lbm	
37	Degrees Superheat	4.3	°F	
38	Capacity Correction	1.0035		
39	Measured Capacity	12820.5	PPH	
40	Slope	136.156	PPH/PSIA	
41	Coefficient	0.96160		
42	Rated Capacity For Measured Set	N/A	PPH	
43				
44			in ²	